

Completion Certificate for Electrical Installations < 50kVA
Certificate No: ARE0157635

Customer Name: CAIRN HOMES MPRN: 10 021 752 310
 Address of Installation: 9/13, LANDLORD, BLOCK C,
 BLACKHALL PLACE
 , DUBLIN 7
 Dublin
 Premises Description: Small Commercial Date of Installation: 25/06/2018

This Certificate is in respect of: Construction & Test of the Installation
 Test only of the Installation

Type of Installation: New Alteration Temporary Supply Other

Number of: Lighting Points Socket Outlets Fixed Appliance Outlets

Polarity and Earthing of all Outlets verified. YES X Verification of RCDs Operation YES X Main Equipotential Bonding Verified for:

	YES	NA
Gas		X
Water	X	
Other		X

Test Record Sheet Nos 0981749

Insert Test Values

Min Insulation Resistance Max Resistance of Protective Conductor

Max Fault Loop Impedance Rating & type of Associated Protective Device

Trip Time 30mA RCDs at 30mA

All new work must be certified in respect of Construction & Testing

Comment or details: RECI Registered Contractor: A0467
 Name: RAYMARK ENGINEERING LTD
 Address: Unit 4, Clonlara Ave, Baldonnell Business Park Naas Rd Dublin 22
 Contact Details: Phone: 01 4583073

Pre-Connection (Pre-Connection tests completed and found to be satisfactory)
 For Electrical Installation: Constructor Tester Date: 04/07/2018

Post-Connection (Post-Connection tests completed and found to be satisfactory)
 For Electrical Installation: Constructor Tester Date: 04/07/2018

Post-Connection Certification:
 'I, RAYMARK ENGINEERING LTD certify that the electrical installation at the above address has been constructed and pre and post- connection tests have been carried out in accordance with the National Rules for electrical Installations (current issue at date of contract) published by the Electro-Technical Council of Ireland, and has been found to be satisfactory. Test records are held by me.'
 Signed *Pascal Mooney* Signature Date: *4-7-2018*

Note:
 This certificate is issued and signed by the person responsible for the construction and testing, or testing only of the installation or a person duly authorised. This certificate should be used only for Electrical Installations < 50kVA. A different certificate is required for other installations. Installations in Agricultural premises require a Supplementary Agricultural Certification form.

The Register of Electrical Contractors of Ireland or Electro-Technical Council of Ireland are not responsible for the installation or for the accuracy of the information given on this certificate. Electrical installations should be checked periodically.